

CIVILTEST ALBURY WODONGA

SOILS ENGINEERING LABORATORY

PO Box 876, Wodonga, Vic, 3689

ABN 31413178755

1 February 2016
16CT133

Next 1 Pty Ltd
C/- Nordcon
P O Box 107
Wodonga, Vic, 3689

Baranduda Grove Estate, Baranduda

SUMMARY OF SITE CLASSIFICATIONS

Lot No.	Classification	Lot No.	Classification
100	H1-D	114	H1-D
101	H1-D	115	H1-D
102	H1-D	116	H1-D
103	H1-D	117	CF/H1-D
104	H1-D	118	CF/H1-D
105	H1-D	119	CF/H1-D
106	H1-D	120	CF/H1-D
107	CF/H1-D	121	CF/H1-D
108	CF/H1-D	122	CF/H1-D
109	CF/H1-D	123	CF/H1-D
110	CF/H1-D	124	CF/H1-D
111	CF/H1-D	125	CF/H1-D
112	H1-D	126	CF/H1-D
113	H1-D	127	CF/H1-D

If more information is required about the contents of this report please contact the undersigned.

** CF denotes **level 1 controlled fill** overlaying a **Class "H1" – Highly Reactive**. The site classification has been undertaken in accordance with **AS 2870-2011**.

Yours Sincerely



Peter Vella