

CIVILTEST ALBURY WODONGA
SOILS ENGINEERING LABORATORY
PO Box 876, Wodonga, Vic, 3689
ABN 31413178755

22 June 2016
16CT860

Streets Developments P/L
C/- Nordcon
P O Box 107
Wodonga, Vic, 3689

Wattle Views Estate, Stage 3

SUMMARY OF SITE CLASSIFICATIONS

Lot No.	Classification
300	M
301	M
302	CF/M
303	CF/M
304	CF/M
305	CF/M
306	CF/M
307	M
308	M
309	M
310	M
311	M
312	M
313	M

If more information is required about the contents of this report please contact the undersigned.

** CF denotes **level 1 controlled fill** overlaying a **Class "M" – Moderately Reactive**. The site classification has been undertaken in accordance with **AS 2870-2011**.

Yours Sincerely



Peter Vella