

# CIVIL TEST ALBURY WODONGA

SOILS ENGINEERING LABORATORY

PO Box 876, Wodonga, Vic, 3689

ABN 31413178755

16 November 2016  
16CT1462

EP TWO Pty Ltd  
C/- Nordcon  
P O Box 107  
Wodonga, Vic, 3689

Daintree Estate, Stage 20.1, Wodonga

## SUMMARY OF SITE CLASSIFICATIONS

Lot No.	Classification	Lot No.	Classification	Lot No.	Classification	Lot No.	Classification
201	H1	211	CF/H1	221	H1	231	CF/H1
202	H1	212	CF/H1	222	H1	232	H1
203	H1	213	CF/H1	223	H1	233	H1
204	H1	214	H1	224	H1	234	H1
205	H1	215	H1	225	H1	235	H1
206	H1	216	H1	226	H1	236	H1
207	CF/H1	217	H1	227	H1		
208	CF/H1	218	H1	228	H1		
209	H1	219	H1	229	H1		
210	CF/H1	220	H1	230	H1		

\*\* CF denotes **level 1 controlled fill**. The site classification has been undertaken in accordance with **AS 2870-2011**.

\*\* Some lots have level 1 controlled fill over a portion of the site, which may not appear in the corresponding borelog as testing occurred in the centre of the lot.

If more information is required about the contents of this report please contact the undersigned.

Yours Sincerely



Peter Vella  
Manager